

#### Notified Body No. 2812

### **Certificate of Constancy of Performance**

#### 2812-CPR-AD5118

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Briton 2320B.T & 2321B.T Overhead door closers

Intended use: For use on fire rated single leaf and double leaf doors TRANSOM MOUNT & DOOR MOUNT PULL SIDE APPLICATIONS.

Essential characteristics	Performance	Harmonised technical specification
	Test Ref's : WIL 327071, 327071-2 Iss 2, 325004,	
	325004-2 & WF 153131 lss 7.	
Self closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 4, 180°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	EN 1154:1996/A1:2002/AC:2006
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	Pass	
5.2.14 Delayed closing	NPD	
(optional)		
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door	Pass	
suitability		
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	
Dangerous Substances	Pass: the materials in the door closer	EN 1154:1996/A1:2002/AC:2006
Annex ZA3	do not contain or release any	
	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	



# Certificate of Constancy of Performance 2812-CPR-AD5118

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Briton 2320B.T Overhead door closer

Intended use: For use on fire rated single leaf and double leaf doors TRANSOM MOUNT PUSH SIDE APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, > 105°	
5.2.8 Overload performance	Pass	EN 4454-4000/A4-0000/A-0-000
5.2.9 Temperature	-15°C to +40°C	EN 1154:1996/A1:2002/AC:2006
dependence		
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	NPD	
5.2.14 Delayed closing	NPD	
(optional)		
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door	Pass	
suitability		
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	EN 4454:4006/A4:2002/AC:2006
Dangerous Substances	Pass: the materials in the door closer	EN 1154:1996/A1:2002/AC:2006
Annex ZA3	do not contain or release any	
	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	



# Certificate of Constancy of Performance 2812-CPR-AD5118

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **Briton 2321B.T Overhead door closers**

Intended use: For use on fire rated single leaf and double leaf doors DOOR MOUNT PUSH SIDE APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, > 105°	
5.2.8 Overload performance	Pass	EN 4454-4000/A4-0000/A-0-000
5.2.9 Temperature	-15°C to +40°C	EN 1154:1996/A1:2002/AC:2006
dependence		
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	Pass	
5.2.14 Delayed closing	NPD	
(optional)		
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door	Pass	
suitability		
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	EN 4454:4006/A4:2002/AC:2006
Dangerous Substances	Pass: the materials in the door closer	EN 1154:1996/A1:2002/AC:2006
Annex ZA3	do not contain or release any	
	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	



### **Certificate of Constancy of Performance**

### 2812-CPR-AD5118

Placed on the Market under the name of:

## Allegion (UK) Ltd Bescot Crescent, Walsall. West Midlands. WS1 4DL

and produced in the manufacturing plant

### K/002

This is coded form and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 29/10/2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the notified product certification body.

Valid to: 31/10/2022

ERO Project Reference: EROWF10064

Paul Duggan Certification Manager



CSF408-NL 5.0