

Notified Body No. 2812

Certificate of Constancy of Performance 2812-CPR-AE0026

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 1130B.TE Electrically powered hold open Door closer (Size 3 to 4)

Intended use:- For use on fire rated single leaf and double leaf doors

DOOR MOUNT PULL SIDE APPLICATION.

DOOR MOUNT PULL SIDE APPLICATION.		
Essential characteristics	Performance	Harmonised technical
		specification
	Test ref's: 636PCT, 135129,	
	WIL 328560, lss 2, WIL 338299 lss 2,	
Ability to valore a	WF No 13131 lss 7 & 149268 lss 2.	
Ability to release	Dave	
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the		
release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General		
5.2.2 Electrical release	Pass	
		EN 1155:1997+A1:2002/AC:2006
requirements		
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.1.11 Temperature Rise	Pass	
5.1.12 Damage	Pass	
5.1.13 Fire / smoke doors	Grade 1	
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Ability to release		
5.2.14.1 corrosion	Grade 3 (96 hours)	
5.2.14.1 corrosion	Pass	
	. 400	
<u>Dangerous Substances</u>	If a reference to dangerous substances is added	EN 1155:1997+A1:2002/AC:2006
Annex ZA3	in the table ZA.1, the following claim is suggested:	LIT 1103.1931 A1.2002/AC.2000
	Pass: the materials in the hinge do not contain or release any dangerous substances in excess of	
	the maximum levels specified in existing European	
	material standards or any national regulations	
	,	



Certificate of Constancy of Performance 2812-CPR-AE0026

Placed on the Market under the Name of

Allegion (UK) Ltd 35 Rocky Lane, Birmingham, West Midlands. B6 5RQ

and produced in the manufacturing plant

K/002

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 21/12/2020 and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: 31/01/2021

ERO Project Reference: EROWF10072



Paul Duggan Certification Manager



CSF408-NL 5.0